

May 12, 2021

To: Worcester Fire Department- Fire Prevention Division

From: Kaitlyn Connole, Deputy Director of Emergency Communications

Re: Declaration of Usage of BDA Class A- Only

The Department of Emergency Communications, as the FCC designated licensee for the City of Worcester P25 trunked radio system is setting forth the following mandate to all newly acquired, newly installed, or existing units replaced for repair of Bi-Directional Amplifier/Emergency Radio In Building Communications Systems will be of FCC class A designation only.