



CITY OF WORCESTER, MASSACHUSETTS



Administration & Finance
Purchasing Division
455 Main Street – Room 201
Worcester, MA 01608
(508) 799-1220
www.worcesterma.gov

October 6, 2021

To All Bidders:

Subject: **Bid No. 7677-D2, Boiler Replacement – Goddard School/WPS**

ADDENDUM NO. 2

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original bid request.

Please find below questions received and responses from the City:

1. Is there a fire alarm company that is used for your system in this school? **JCI**
2. Clarification is needed on the drawing for the existing CO Detectors and will the FACP panel except the new detectors? **The design is based on the assumption no carbon monoxide detectors exist. If devices are present, monitored by the existing fire alarm system, fully operational and within close proximity of the new boilers, the device(s) can be reused. However, if the existing devices do not meet the requirements defined, new carbon monoxide detectors are required. Regarding the question of the existing fire alarm control panel being able to accept new detectors, this investigation should be part of the bidding process and accomplished by the prospective contractors.**

Bidders are requested to acknowledge and/or include this addendum with bid. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Danielle Wagner
Assistant Purchasing Director