



CITY OF WORCESTER, MASSACHUSETTS
Administration & Finance
Purchasing Division
455 Main Street – Worcester, MA 01608
(508) 799-1220
www.worcesterma.gov



November 8, 2021

To All Bidders:

Subject: **Bid No. 7699-D2, Fire Alarm Upgrades – City Hall / DPF**

ADDENDUM NO. 2

To Whom It May Concern:

PLEASE SEE BELOW GENERAL BID CLARIFICATIONS, INCLUDING QUESTIONS RECEIVED AND RESPONSES FROM CITY

1. Q: Do these annunciators have microphones?
A: All three annunciators need microphone capability.
2. Q: Is the wiring shown on riser drawing E2.0A and E2.0B is sufficient for these type of annunciators?
A: Provide five (5) 18/2 TSP cables from the main fire alarm control panel to each of the three (3) project annunciators.

Specification Items:

1. Section 01.73.29 CUTTING AND PATCHING, Paragraph 3.03, Item D.3 **REPLACE** with the following text:

“Paint surfaces where existing fire alarm conduit, devices or related items are removed, using paint systems specified in Section 09.90.00 – PAINTING. Work may be limited to the area affected by the Work; repainting the entire wall or ceiling is not required. Match existing paint colors and sheen.”
2. Section 08.20.00 – DOORS, FRAMES AND HARDWARE, Paragraph 2.01, Item C.1, ADD new item (b.) to read:

“(b) Size: 18” x 24” ”
3. Section 09.90.00 – PAINTING, Paragraph 1.02, **ADD** new item 3 to read:

“3. Touch up painting where existing materials are removed or cutting/patching is performed, as specified in Section 01.73.29.”

Bidders are requested to acknowledge and/or include this addendum with bid. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro
Purchasing Director