

# CITY OF WORCESTER, MASSACHUSETTS



Administration & Finance Purchasing Division 455 Main Street – Room 201 Worcester, MA 01608 (508) 799-1220 www.worcesterma.gov

To All Bidders:

Subject: Bid No. 7770-W2, Resurfacing Streets (M22-5) / DPWP

**ADDENDUM NO. 2** 

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

PLEASE SEE BELOW GENERAL BID CLARIFICATION INCLUDING QUESTIONS RECEIVED
 AND RESPONSES FROM CITY

Please specify which decorative fixture from the Worcester City Standards will be used for bid item 820.0000, QTY-6.

Answer: please see attached lighting specification sheet

Bidders are requested to acknowledge and/or include this addendum with bid. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro Purchasing Director

# 22'-2" (nominal height) 20'-6" 15'-6" Ø1'-5"

# Specifications

POS T DESCRIPTION

The lighting post shall be cast iron and steel construction, massively tapered with a deep, 16-flute steel shaft and a classic 16-flute cast iron base. The post shall be provided with (1) OUC single arm, 45" from post center to luminaire center, (1) Boston Harbour QSM leveling filter factory attached to the luminaire, (1) 24" breakaway banner arm, (1) bott on eyebolt and (1) GFI weatherproof receptacle with

breakaway banner arm, (1) boit on eyeboot and (1) GFI weatherproof receptacle with large, in-use cover.

MATERIALS

The post material shall be ASTM A48, Class 30 cast iron, formed true to the pattern with complete detail. All esolsed hardware shall be stainless steel, Anchor bolts to be completely hot dip galvanized. Partially galvanized bolts are not acceptable.

<u>DIMENSIONS</u>
The post shall be 20'-8" in height with a 17" diameter base. The post shall taper from a  $\emptyset$ 7" at the top of the base to a  $\emptyset$ 4.5" at the post top. An integral  $\emptyset$ 3'x4" tenon shall be provided at the top for arm mounting.

be provided at the top the second sec

FINISH
The entire post assembly shall be standard Holophane black.

- Interenter pout assembly senia ne standard notophane black.

  <u>LUMINAME DESCRIPTION</u>

   Memphis Teardrop LED 2 Series


   12,000 Lumens w/Luplight, 4 COBs, 4000k CCT, Auto-Sensing Voltage (120-277)

   Black finish, Teardrop glass, Type 3 Asymmetric, Quick Lock Stem mount

## **Accessory Mounting Detail**

	Orientation	Height
BANNER ARM	0°	15'-6"
EYEBOLT	0°	11'-6"
RECEPTACLE	180°	11'-0"

# **Anchorage Detail**



# DO NOT USE TO SET ANCHOR BOLTS CONTACT CUSTOMER SERVICE FOR TEMPLATE

# Catalog #s: RFD209410

Lum/Lamp: MPL2P20U40KASBKTG3S BHDF13200BKP7 FACT ATT Arm: CAM72/1CABKH

Pole: NYS21FTB17P05BK R132C S186A E138A

Receptacle: FGIUL-SBKH Banner Arm: BBA24BOH4MXXBK

Eyebolt: BAEB

Anchor Bolts: AB-31-4

"CUSTOMER: PLEASE VERIFY PLACEMENT OF ACCESSORIES IN THE "ACCESSORY MOUNTING DETAIL" TABLE - INFORMATION NECESSARY FOR ENSURING ORDER IS PLACED AS NEEDED."

Customer Signature