

March 15, 2023

To All Bidders:

Subject: <u>Bid No. 7970-W3, Arena Seating Installation – DCU Center / DPF</u>

ADDENDUM NO. 4

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

 BID DUE DATE HAS BEEN EXTENDED TO WEDNESDAY, MARCH 22, 2023 AT 10:00 AM


SPECIFICATION ADDENDA

For work to be performed at and:

- 1. At Section 02 41 19 Selective Demolition Arena Part 3 Execution 3.4 Selective Demolition, General ADD, "D. At Seating Section 112 demolish and dispose of existing aluminum decking as shown in SKA-1 of this addenda." AND "E. Demolish and dispose of existing deck supports. Do NOT discard steel I-beams."
- 2. At Section 12 63 00 Arena Seating Installation Part 3 Execution 3.2 Installation ADD "F. Resurface existing spanner decks in Section 112 to match new bleacher aluminum; see SKA-1 of this addenda. All installation materials and fasteners provided by chair manufacturer, Hussey Seating. Drill holes for new deck supports into existing steel I-beams. Bolt together deck supports, aluminum nosing, and steel riser. Install new decking and end caps. Attach rail sockets and front rails. Drill through decking to install new chairs and attach backer plates per manufacturers requirements."



DRAWING ADDENDA



SKA – 1 Section 112 Spanner Deck Resurfacing

March 15, 2023

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro Purchasing Director