



The City of **WORCESTER**

Administration & Finance – Purchasing Division
Christopher J. Gagliastro, MCPPO – Purchasing Director
455 Main Street, Room 201, Worcester, MA 01608
P | 508-799-1220
purchasing@worcesterma.gov

June 15, 2023

To All Bidders:

Subject: **Bid No. 7978-W3, South Worcester Playground Improvements – Phase III / DPWP**

ADDENDUM NO. 3

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **PLEASE SEE BELOW QUESTIONS RECEIVED AND RESPONSES FROM CITY**

After reviewing the subsurface Evaluation Report, there is recommendation to remove fill at boring SB-3 & SB-4 , can you look into this ? one option is a cubic yard quantity for remove and replace the fill/unsuitable material to carry in the bid ?? please advise

Answer: Refer to Earthwork Specification 31 00 00.

The topsoil removal; can the topsoil be screened and reused?

Answer: Refer to Earthwork Specification 31 00 00.

Can the concrete wall be precast or does it have to be poured in place?

Answer: Precast can be considered during shop review process as an equal.

Are all site amenities such as, fence, basketball hoops, benches etc. to removed and stacked? If so where does the contractor have to bring the old equipment

Answer: Contractor shall remove and legally dispose offsite, items not required for finish work, unless not to be reused, stacked, stored, salvaged or as directed by Owner.

Are there any soil testing requirements for contaminated soils on this project?

Answer: No contaminated soils encountered during evaluation/borings or known.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro - Purchasing Director