

June 13, 2023	June	13,	20	)23
---------------	------	-----	----	-----

To All Bidders:

Subject: 7981-M3 Sewer Rehabilitation – Various Streets (S23-3) / DPW & Parks

## **ADDENDUM NO. 3**

To Whom It May Concern:

With reference to our proposal request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

• Please see attached document for Addendum #3 relating to clarification of Bid Item 126 (Gravel Borrow.)

Proposers are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Maureen McKeon Assistant Purchasing Director

## CITY OF WORCESTER, MASSACHUSETTS

# VARIOUS STREETS CONSTRUCTION AND RECONSTRUCTION OF SANITARY AND SURFACE SEWERS AND WATERMAIN SEWER REPLACEMENT PROJECT CONTRACT NO. S23-3 ARPA BID NO. 7981-M3

#### ADDENDUM NO. 3

\*

To be considered as part of the contract drawings and specifications for the Various Streets Connstruction and Reconstruction of Sanitary and Surface Sewers and Watermain Replacment Project, Contract S23-3, Bid #7981-M3.

# **QUESTIONS**

- Q2. Please confirm that Bid Item 126 (Gravel Borrow) is to be used for the 12-inch of gravel beneath the temporary asphalt patch.
- A2. The gravel borrow item is intended to be used for the paving sub-base. Additional quantity was included for backfill if unsuitable soils were encountered in the excavated trench.

## **END OF ADDENDUM NO. 3**

P:\MA\Worcester MA\2220378 Various Streets Sewer Replacement\Bidding\Contract S23-3\Addenda\Addendum No. 3\Addendum No. 3 \ Worcester Various Streets S23-3.Docx