



June 16, 2023

To All Proposers:

Subject: **BID #: 8023-M3, Domestic Hot Water Tank Replacement – DCU Center / DPF**

ADDENDUM NO. 2

To Whom It May Concern:

With reference to our proposal request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

● **PLEASE SEE BELOW GENERAL BID CLARIFICATIONS**

Delete Language Reading:

GENERAL NOTE:

1. CONTRACTOR SHALL PROVIDE MEANS AND METHODS TO ENSURE BUILDING DOMESTIC HOT WATER SUPPLY IS MAINTAINED. MEANS AND METHODS MAY INCLUDE BUT ARE NOT LIMITED TO OFF HOURS WORK, PRE-FABRICATION OF PIPING ASSEMBLIES, OR TEMPORARY POTABLE WATER HOSE BEARING NSF LISTING AND RATED TO 150 F OR MORE.

And replace it with:

GENERAL NOTE:

1. Contractor shall schedule and sequence their work such that building domestic hot water is maintained as follows:
2. All full DHW shutdowns must be between the hours of 1:00 am and 5:00 am
3. Full capacity to the building during the following time periods due to events will be taking place on the third floor of the convention center:

June 19-22, 2023 (Monday-Thursday) June 26-27, 2023 (Monday-Tuesday) July 8, 2023 (Saturday) July 29, 29, 2023 (Saturday) August 11-13, 2023 (Friday-Sunday) August 17-19, 2023 (Thursday-Saturday)

4. Reduced temporary DHW capacity is acceptable to owner other than as required above. Contractor shall achieve this by temporarily piping the DHW boiler output to the 140 HWS and mixing valve inlet with 1-1/2 copper pipe. Worcester Facilities takes no exception to the reduced temporary DHW flow rate available through this measure.



5. Contractor shall adjust schedule based on above and shall include all costs in their bid to meet these requirements, including but not limited to larger crews, or prolonged schedules to hit the work windows outlined above.

Proposers are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro
Purchasing Director