



The City of  
**WORCESTER**

Administration & Finance – Purchasing Division  
Christopher J. Gagliastro, MCPPO – Purchasing Director  
455 Main Street, Room 201, Worcester, MA 01608  
P | 508-799-1220  
[purchasing@worcesterma.gov](mailto:purchasing@worcesterma.gov)

August 24, 2023

To All Bidders:

Subject: **8055-M4, East Park Improvements-Little League Field/DPWP**

**ADDENDUM NO. 3**

To Whom It May Concern:

With reference to our proposal request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **PLEASE SEE BELOW FOR GENERAL BID CLARIFICATIONS.**

Proposers are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Maureen McKeon  
Assistant Purchasing Director

### **ADDENDUM NUMBER THREE**

**Date:** August 24, 2023  
**Project:** East Park Improvements – Little League Field  
City of Worcester Dept. of Public Works and Parks; Parks, Recreation and Cemetery Div.

#### **General Bid Questions:**

**Question1:** The drawing from addendum #2 E-1 do not identify and wire sizes,  
Incoming service  
Wire to sports lighting poles  
Wire size to the dugout power and lighting  
Wire size to the parking lot lights  
Wire size for the scoreboard

**Answer:** See Attached Chart.

DESCRIPTION	CABLE	CONDUIT
SERVICE	3-350KCMIL CU & 1/0 GND	4"PVC
SPORTS LIGHT POLE A1 - LIGHTS	3-#8 AWG & #8 GND	1- 2" PVC
SPORTS LIGHT POLE A1 - SECURITY LIGHTS	3-#12 AWG & #12 GND	
SPORTS LIGHT POLE A1 - CAMERA	3-#12 AWG & #12 GND	1- 1" PVC
SPORTS LIGHT POLE A2 - LIGHTS	#3-8 AWG & #8 GND	1- 2" PVC
SPORTS LIGHT POLE A2 - SECURITY LIGHTS	3-#12 AWG & #12 GND	
SPORTS LIGHT POLE A2 - CAMERA	3-#12 AWG & #12 GND	1- 1" PVC
SPORTS LIGHT POLE B1 - LIGHTS	3-#4 AWG & #4 GND	1- 2" PVC
SPORTS LIGHT POLE B1 - SECURITY LIGHTS	3-#12 AWG & #12 GND	
SPORTS LIGHT POLE B1 - CAMERA	3-#12 AWG & #12 GND	1- 1" PVC
SPORTS LIGHT POLE B2 - LIGHTS	3-#4 AWG & #4 GND	1- 2" PVC
SPORTS LIGHT POLE B2 - SECURITY LIGHTS	3-#12 AWG & #12 GND	
SPORTS LIGHT POLE B2 - CAMERA	3-#12 AWG & #12 GND	1- 1" PVC
SPORTS LIGHT POLE B2 - LIGHTS - FUTURE	3-#2 AWG & #2 GND	1- 2" PVC
SPORTS LIGHT POLE B2 - LIGHTS - FUTURE	3-#12 AWG & #12 GND	
DUGOUT 1ST BASE -	3-#10 AWG & #10 GND	1- 1" PVC
DUGOUT 3RD BASE -	3-#10 AWG & #10 GND	1- 1" PVC
SCOREBOARD -	3-#10 AWG & #10 GND	1- 1" PVC
PARKING LOT LIGHTS -	3-#10 AWG & #10 GND	1- 2" PVC

Question2: On drawing E-2 the oneline drawing also has no wire sizing shown.

Answer: **See response/chart to Question 1.**

Question3: On drawing E-7 there are ductbank details and are identified by lettering. The drawing E-1 does not identify where the ductbank details belong for installation of the PVC.

Answer: **Consider ductbank details as typical, application depending on field layout and routing as determine by contractor's means and methods.**

**END OF ADDENDUM THREE.**