



February 5, 2024

To All Proposers:

Subject: **Bid #: 8134-W4, Lighting Installation – Madison Street Bridge / E.D.**

ADDENDUM NO. 3

To Whom It May Concern:

With reference to our proposal request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

PLEASE FIND BELOW GENERAL BID CLARIFICATION(S) AND QUESTIONS RECEIVED AND RESPONSES FROM CITY

General Bid Clarification

AMEND: DETAIL 2 CONTROLS DIAGRAM, SHEET E601

Delete “10FT JUMPER CABLE” between fixtures and add “6.5FT JUMPER CABLE” between fixtures.

Question: RFI #10 re: Addendum 2 Question 8/Answer 8: This cellular modem will be provided by the City of Worcester since there is no specification and maybe required for the city to purchase it direct. Please review and advise.

Answer 8: The Contractor shall provide the CAT5E/CAT6 cable to connect to the “Local Area Network” as shown in the drawings. The “Local Area Network” shall be a cellular modem that will be provided by Owner. Contractor to provide second dedicated receptacle within electrical cabinet to power cellular modem in addition to receptacle shown in drawings.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro
Purchasing Director