

CITY OF WORCESTER, MASSACHUSETTS

Shrewsbury Street Sewer Rehabilitation Sewer Rehabilitation Project  
Contract S24-1-ARPA  
Bid No. 8180-W4

ADDENDUM NO. 4

.....  
To be considered as part of the contract drawings and specifications for the Shrewsbury Street  
Sewer Rehabilitation Sewer Rehabilitation Project, dated April 2024:

**QUESTIONS**

- Q1. Is exterior grouting required where the manhole and/or structure shows no signs of infiltration?
- A1. **The Engineer shall determine any modifications to the scope of work for exterior grouting of sewer manholes and structures based upon observed conditions. Such modifications shall be made on a case-by-case basis. At a minimum, grout injection shall be performed at all pipe connections as shown on the Contract Drawings.**

END OF ADDENDUM NO. 4