

May 21, 2024

To All Bidders:

Subject: Bid No. 8193-M4 Sewer Line Repairs (CIPP) / WPS

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- Questions received by our office and answers from the City:
 - 1. Are the pipes that are being lined sewer main lines or laterals?

The pipes to be lined extend from inside the WPS building(s) to the city main lines and would be considered laterals.

2. If they are sewer main lines does the lining start and end at manholes?

The lining starts at a cleanout on WPS Property and ends at a manhole in the public right-of-way.

3. If there are no manholes will the city be installing manholes before the lining takes place?

The City will not be installing manholes. The lining will start from the cleanout on WPS property and proceed toward the right-of-way.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Stephen R. McDonald Assistant Purchasing Director