

September 30, 2024

To All Bidders:

Subject: Bid No. 8245-M5, Shore Drive Park & Sidewalk Improvements / DPW&P

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

General Bid Clarification:

- 1. In the Contract Documents Special Provisions, Section 323223, Segmental Retaining Walls, PART 2 Products, 2.1 Segmental Retaining Wall Units, Add the Following:
 - "G. All units shall be wet-cast precast modular retaining wall units conforming to ASTM C 1776."
- **2.** In the Contract Documents Special Provisions, Section 323223, Segmental Retaining Walls, PART 2 Products, 2.1 Segmental Retaining Wall Units, **Add the Following:**
 - "H. Mockups:
 - A. Build mockups to verify selections made under sample submittals and to demonstrate aesthetic effects.
 - B. Subject to compliance with requirements, approved mockups may become part of the completed work if undisturbed at time of Substantial Completion."

Very truly yours,

Stephen R. McDonald Assistant Purchasing Director