

October 16, 2024

To All Bidders:

Subject: Bid No. 8300-M5, Stormwater Improvements S24-2 / DSR-ARPA

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

Questions received by this office, with answers from the City:

1. Q: Can you put an RFI into the City of Worcester and ask if the listed flows for each device (4.5 cfs, 14 cfs) are treatment flow rates or maximum conveyance flow rates?

A: The listed flows for each device are for peak flow rates.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Stephen R. McDonald Assistant Purchasing Director