

November 20, 2024

To All Bidders:

Subject: <u>Bid No. 8307-W5, Sound System Replacement – DCU Center / DPF</u>

**ADDENDUM NO. 5** 

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

## PLEASE SEE BELOW QUESTIONS RECEIVED AND RESPONSES FROM CITY

- 1. Specification 27 41 16 2.9.D indicates a quantity of (4) EAW Power Network Distro Boxes. Sheets E5.0 and E8.0 indicate power allocation for (4) Power/Network Distro Boxes. Each Power Network Distro Box is capable of powering up to 12 EAW Adaptive Modules for a total of (48) modules. Per the sheet AV11.09, each array consists of (6) Anna and (3) Otto modules. Sheets AV11.1, AV1.4.1A, and AV1.1.1B indicate a total of (6) arrays for a total of (54) modules. Sheet AV11.1 indicates each array will have a feature a dedicated Power/Network Distro Box. Please clarify.
  - A. The EAW Power Network Distro Boxes described in 27 41 16, 2.9, D are only for use when the loudspeakers are used in the end-stage configuration. Type 2 switches as shown on AVI 111 will permanently mount to the Type 20/21 loudspeaker rigging frames reference AVI 190
- Sheet AVI 1.11 indicates (12) Type 2 network switches. Are these devices in addition to the switches which are included in the EAW Power Network Distro boxes?
  A Yes. These switches are in addition. See response to previous question above.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro Purchasing Director