



The City of **WORCESTER**

Administration & Finance – Purchasing Division
Christopher J. Gagliastro, MCPPO – Purchasing Director
455 Main Street, Room 201, Worcester, MA 01608
P | 508-799-1220
purchasing@worcesterma.gov

December 5, 2024

To All Bidders:

Subject: **Bid No. 8331-M5 Door & Hardware Replacement / WPS**

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

The Bid Opening Date has been moved to Wednesday, December 18, 2024. The time remains at 10:00am.

Questions received by our office and answers from the City:

- Are these doors replacement of existing doors or new installations? ***Existing doors or replacement of pre-existing doors***
- Are they doors with frames or just doors slabs? ***Door slabs with new hinges (see 2.1.2 INTERIOR DOORS in bid package).***
- Can we schedule a walkthrough for the remaining ten buildings? ***Yes, there will be two subsequent walkthroughs. The first will be Monday, December 9, 2024 @ 3:00 PM, for the following schools: City View, Lake View, Grafton St. School, Union Hill and Vernon Hill School. The second will be Tuesday, December 10, 2024 @ 3:00 PM, for the remaining schools: Burncoat Prep School, Francis McGrath Elementary School, Tatnuck Magnet School and Goddard.***

<i>Walkthrough #2</i>	<i>Walkthrough #3</i>
<i>City View Discovery School</i>	<i>Burncoat Prep School,</i>
<i>Lake View School</i>	<i>Francis J McGrath Elementary School,</i>
<i>Grafton St. School,</i>	<i>Flagg St. School</i>
<i>Union Hill School</i>	<i>Tatnuck Magnet School</i>
<i>Vernon Hill School.</i>	<i>Goddard School Of Science & Technology</i>



The City of **WORCESTER**

Administration & Finance – Purchasing Division
Christopher J. Gagliastro, MCPPO – Purchasing Director
455 Main Street, Room 201, Worcester, MA 01608
P | 508-799-1220
purchasing@worcesterma.gov

- For doors that aren't closing properly due to worn-out hinges, are the installers expected to replace the hinges? *No, these doors will be addressed by WPS staff prior to installation of the new locks and/or door hardware.*
- We noticed several doors missing closers that were previously installed. Will these doors require new door closers? *No, the City is not expecting new door closers to be installed.*
- Are you requesting a restricted keyway or open keyway by Schlage? *The specified keyway would be Schlage Everest 29 T keyway in FSIC.*

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Stephen R. McDonald
Assistant Purchasing Director