

April 28, 2025

To All Bidders:

Subject: Bid No. 8422-M5 Fire Department Parking Lot Repairs / WFD

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

Questions Received by this Office, and Answers from the City:

- 1. Q: Line 3 mentions 6-12 inches of gravel base and Line 5 mentions 12-18 inches of aggregate base which one are we supposed to carry on our bid?
 - A: Please carry the 12-18 inches of aggregate base.
- 2. Q: Also, what are the limits of work? We have no measurements of any of the aprons so that we can bid this properly and competitively.
 - A: Size of areas needing repairs are as follows:
 - a. Grove St approximately 519 Sq yds
 - b. West Boylston St approximately 695 sq yds
 - c. (Add Alternate) Park Ave approximately 550 sq yds

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Stephen R. McDonald Assistant Purchasing Director