

April 30, 2025

To All Bidders:

Subject: Bid No. 8428-W5, Access Control Upgrades – City Hall / DPF

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

PLEASE SEE BELOW QUESTIONS RECEIVED AND RESPONSES FROM CITY:

- What is acceptable for conduit/ wiremold to conceal wires on concrete walls? Is it acceptable on interior walls/ceilings in offices where there is no drop tile?
 - No concrete walls are within the scope of the project. No conduit or wire molds should be used, all walls and ceilings shall be snaked.
- Are we allowed to cut access panel to snake cabling?
 - o Cutting access panels is allowed but prior approval from City is required.
- Who is responsible for patch and paint?
 - o Awarded bidder is responsible for patching and painting.
- Who is providing network switches?
 - o The city is responsible for any network switches

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro Purchasing Director