



June 20, 2025

To All Bidders:

Subject: **Bid #: 8467-W6, RTU Replacement – Franklin Street Fire Station / WFD**

**ADDENDUM NO. 1**

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original request.

Please see below questions received and responses from City:

*Question: On drawing M 001 the control diagram and sequence call for DDC controls. Is it the intent for these units be tied into or controlled through the city's existing Alerton BMS system?*

*Answer: The units have integral factory mounted controls and will be connected back to the existing thermostats/control wiring. The intent is to maintain the existing controls strategies.*

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours

Christopher J. Gagliastro  
Purchasing Director