

November 24, 2025

To All Bidders:

Subject: <u>Bid No. 8589-M6-Camera Installation / WPS</u>

ADDENDUM NO. 3

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

Questions Received by this Office, and Answers from The City:

- Q: Are there any known asbestos concerns in the areas where cable will be run and cameras will be installed? Will vendors be required to conduct asbestos testing prior to installation?
 A: Asbestos Management Plan Binders are located in the main office of every building. This binder includes testing of building materials for asbestos, note that this is not a comprehensive list of materials and if a material is not listed that it likely has not been tested. If the material has not been tested or confirmed positive for asbestos, the vendor must not disturb the material. If such materials are disturbed, the Vendor is responsible for all costs associated with the cleanup and verification testing (by WPS vendor of choice) to ensure cleanup is complete. The vendor must sign a copy of the contractor notification letter prior to performing work in any of the buildings.
- 2. Q: What are the licensing requirements for this project? Specifically, is a Massachusetts S License required for the work?
 - A: All requirements are as provided in the specification.
- 3. Q: Are all cables required to be run in piping conduit, or are there specific areas where conduit is required versus optional?
 - A: Please refer to the specification. Any wiring done below the ceiling must be piped in EMT.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Stephen R. McDonald Assistant Purchasing Director