

April 15, 2026

To All Bidders:

Subject: **Bid #: 8639-W6, AST Installation – Moy Ranch Garage Demolition / DPW**

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original request.

- **PLEASE SEE QUESTIONS RECEIVED AND RESPONSES FROM CITY:**

1) A question came up from my Equipment Vendor:

C-2 shows the AST having a Standard Stair that we will assume is to fill the tank. If you look at the D-1 Drawings, there are (5) couplings labeled A that can be used for filling the tank. If the intent is to fill from the stairs then there is no way you can fill the 2nd compartment from the stairs. It looks like Remote fills would be better option

Answer: The City's specifications read: "The stairway shall be custom fabricated to the tank and comply with OSHA regulations and conform with the tank supplier requirements. The stairway plan will be submitted to the City and Engineer prior to installation for review and comment."

The stairs depend on the tank selected per the performance specification by the bidder. The bidder will propose a tank that meets the performance specification and the stairs will have to meet the requirements of that particular supplier of the tank.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours

Christopher J. Gagliastro
Purchasing Director