



March 19, 2026

To All Bidders:

Subject: **Bid No. 8648-J6 – Toilet Fixture Replacement – Institute Park / DPRC**

ADDENDUM NO. 2

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

Questions received by this office and responses from The City:

1. Q: The project drawings show new wall mount toilets connecting to existing fixture carriers. The current configuration for the existing toilets do not have toilet carriers installed. Please clarify if new carriers are to be installed or will the fixture specification be replaced with one suitable for the current piping configuration?

A: Toilet fixtures shall be mounted to existing concrete partition to match existing. No fixture carriers are required.

Provide new holes for bolt pattern if required. Concrete grout any existing hole openings not used.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Jerry Kucera
Buyer