



June 29, 2026

To All Bidders:

Subject: **Bid No. 8726-J7 – Resurfacing – Ultra Thin Bonded Wearing Course / DPW**

ADDENDUM NO. 2

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

General Bid Clarification:

1. Please use the updated P-sheets attached to this document.

Questions Received by this Office and Answers from the City:

1. Q: There is no spec for the UTBO or the emulsion included in the special provisions. Please provide specs or tell the bidders to follow MassDOT specs. MassDOT is Type 2 Polymer (12.5mm Mix Design) with CRS-1P emulsion applied at a rate of 0.18 – 0.22 gallons per square yard.
 - A: Use 9.5mm Mix Design - Type 2 (No Polymer) for the Binder with CRS-1P emulsion applied at a rate of 0.18 – 0.22 gallons per square yard. Emulsion and Gutter Milling will be incidental to the 492.00
2. Q: Will a control strip be required for the UTBO placement? If so, what are the parameters?
 - A: No Control Strip will be required.
3. Q: Please provide a spec for Item 490 – Polymer & Crumb rubber modified asphalt crack sealant compound with reinforcing fibers?
 - A: See City Standard Specifications 490. Crack Sealant
4. Q: Please detail what the intended use of Items 116 – Excavation, 126 – Gravel Borrow & 402 – Fine Grading, Rolling & Finishing will be used for? If you are digging down to gravel in the roadway, should Item 422.2 – 12.5mm L2 superpave be added?
 - A: They are for full depth patching as required by Engineer. The contractor shall use item 424 for full depth patching and other misc patching work using 2 lifts: 12.5 SSC for the binder and 9.5 SSC for the top.



5. Q: Please clarify the completion date 6-30-27 or 11-15-27?
 - **A: 6-30-2027 will be the Completion Date.**
6. Q: Will the contractor be required to install temporary tape on the completed UTBO for traffic accommodations?
 - **A: Yes. Temporary Tape will Mimic the pre existing striping and will be incidental to item 492.**
7. Q: There is no final striping in the contract. Who is responsible for the permanent striping? If the paving contractor is not responsible, can the city give them a letter stating their work is complete on each street once the UTBO is placed to remove them from any liability that should arise from the lack of permanent striping that is out of their control?
 - **A: Permanent Striping has been added to the pricing sheets.**

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Jerry Kucera
Buyer

D26-1 - Ultra Thin Bonded Wearing Course

THE BIDDER MUST FILL IN THESE UNIT PRICES. Also carry out all extensions and fill in "Computed Totals."
In case of error or discrepancies, UNIT PRICES govern and written works take precedence over figures.

ITEM NUMBER AND DESCRIPTION	ESTIMATED QUANTITY	COMPUTED TOTALS
116.0000 EXCAVATION		
_____ Dollars	900.00	\$ _____
(\$ _____) CY		
126.0000 GRAVEL BORROW		
_____ Dollars	700.00	\$ _____
(\$ _____) CY		
235.0000 CATCH BASIN FRAME & GRATE		
_____ Dollars	10.00	\$ _____
(\$ _____) EA		
236.0000 MANHOLE FRAME & COVER		
_____ Dollars	25.00	\$ _____
(\$ _____) EA		
252.1000 MANHOLE ADJUSTMENT 12 INCH OR LESS GRAVEL		
_____ Dollars	10.00	\$ _____
(\$ _____) EA		
254.1000 CATCH BASIN ADJUST TO LINE AND/OR GRADE 12 INCH OR LESS, GRAVEL		
_____ Dollars	5.00	\$ _____
(\$ _____) EA		
304.0400 REPLACING 4" - 12" GATE VALVE BOX, GRAVEL BASE		
_____ Dollars	5.00	\$ _____
(\$ _____) EA		
304.0800 WATER BOX ADJUST TO GRADE, GRAVEL BASE		
_____ Dollars	15.00	\$ _____
(\$ _____) EA		
402.0000 FINE GRADING, ROLLING AND FINISHING		
_____ Dollars	2,000.00	\$ _____
(\$ _____) SY		

D26-1 - Ultra Thin Bonded Wearing Course

ITEM NUMBER AND DESCRIPTION		ESTIMATED QUANTITY	COMPUTED TOTALS
403.0000	GRINDING AND MILLING 1-1/2 INCH		
		Dollars	2,000.00 \$
	(\$) SY		
416.0000	CURB REMOVE AND RESET		
		Dollars	200.00 \$
	(\$) LF		
422.1000	SUPERPAVE 9.5 MM LEVEL 2		
		Dollars	400.00 \$
	(\$) TN		
424.0000	BITUMINOUS CONCRETE DRIVEWAY & VARIOUS AREA		
		Dollars	600.00 \$
	(\$) TN		
434.0000	SAWING PAVEMENT		
		Dollars	2,000.00 \$
	(\$) LF		
483.0000	REPLACING GAS BOX, GRAVEL BASE		
		Dollars	15.00 \$
	(\$) EA		
490.0000	POLYMER AND CRUMB RUBBER MODIFIED ASPHALT CRACK SEALANT COMPOUND WITH REINFORCING FIBERS		
		Dollars	900.00 \$
	(\$) Gal.		
492.0000	ULTRA THIN HMA/BONDED WEARING COURSE		
		Dollars	57,500.00 \$
	(\$) SY		
501.0000	4 INCH REFLECTORIZED WHITE LINE (THERMOPLASTIC)		
		Dollars	10,000.00 \$
	(\$) LF		

D26-1 - Ultra Thin Bonded Wearing Course

ITEM NUMBER AND DESCRIPTION		ESTIMATED QUANTITY	COMPUTED TOTALS
502.0000	4 INCH REFLECTORIZED YELLOW LINE (THERMOPLASTIC)		
		Dollars	15,000.00 \$
	(\$) LF		
503.0000	12 INCH REFLECTORIZED WHITE LINE (THERMOPLASTIC)		
		Dollars	2,000.00 \$
	(\$) LF		
504.5000	PAVEMENT MARKING REMOVAL		
		Dollars	15,000.00 \$
	(\$) SF		
900.0000	Lump Sum Reserve		
		eighty-four thousand eight hundred and xx / Dollars	\$ 84,800.00
	100		

TOTAL BID PRICE INCLUDING CONTINGENCY

_____ Dollars and _____ Cents
(amount in words)

\$ _____
(amount in figures)

This proposal is based on provisions of the following addenda:

No. _____

No. _____

No. _____

No. _____

All amounts and totals given above will be subject to verification by the City. In case of variation between Unit Bid Price and Totals shown by the Bidder, the Unit Price written in words will be considered to be the bid.

The City reserves the right to reject any and all bids, wholly or in part, and to make awards in a manner deemed in the best interests of the City.

The above estimated quantities form an approximate statement of the extent of the work to be done, based upon the estimate of the Contracting Officer. The City does not expressly or by implication agree that the actual quantity of work will correspond therewith, but reserves the right to increase or decrease the quantity of any class or portion of the work, as may be deemed necessary by the Contracting Officer.