



The City of **WORCESTER**

Administration & Finance – Purchasing Division
Christopher J. Gagliastro, MCPPO – Purchasing Director
455 Main Street, Room 201, Worcester, MA 01608
P | 508-799-1220
purchasing@worcesterma.gov

September 1, 2026

To All Bidders:

Subject: **Bid No. 8797-W7, HVAC Upgrades – Hope Cemetery Building / DPRC**

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **Please see below questions received and clarifications from City:**

Question: HVAC specification 23 00 00 2.8 I state that the refrigerant piping insulation shall meet the requirements of Section 23 07 00.

Section 23 07 00 was not put in the HVAC specification.

Please update the HVAC specifications to include this section.

Answer: Specification section 230700 shall be removed. The refrigerant suction line pipe insulation shall be 1-inch-thick flexible, closed-cell elastomeric foam insulation.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions, and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro
Purchasing Director