



The City of
WORCESTER

Administration & Finance – Purchasing Division
Christopher J. Gagliastro, MCPPO – Purchasing Director
455 Main Street, Room 201, Worcester, MA 01608
P | 508-799-1220
purchasing@worcesterma.gov

September 18, 2026

To All Bidders:

Subject: **Bid No. 8798-W7, Entrance Door Replacement – Senior Center / DPF**

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **PLEASE SEE ATTACHED GENERAL BID CLARIFICATIONS**

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions, and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro
Purchasing Director

PART 1 - GENERAL

This addendum modifies, amends, and supplements designated parts of the Contract Documents for the above project and is hereby made part thereof by reference and shall be as binding as though inserted in locations designated hereunder.

It shall be the responsibility of the bidders to notify all subcontractors and suppliers he proposes to use for the various parts of the work for any changes or modifications contained in this addendum. No claim for additional compensation because of lack of knowledge of the contents of this addendum will be considered.

PART 2 – SPECIFICATIONS

1. SECTION 01 10 00 – SUMMARY OF WORK

Page 3, 3.01 PREPARATION & PROTECTION

Insert: “L. Contractor to provide temporary doors and/or enclosures for weather protection and security though the construction until the new doors are operational.
Provide temporary heat as required.”

2. SECTION 08 41 13 – ALUMINUM FRAMED ENTRANCES AND STOREFRONTS

Page 4, 2.2.A:

Delete: “thermally broken”

Page 4, 2.2.A.1:

Delete: Item 1. in its entirety

Insert: “1. Kawneer model ‘500 Wide Stile’ entrance door”

Page 4, 2.2.A.2:

Delete: Item 2. in its entirety

Insert: “2. EFCO model ‘D500’ entrance door”

Page 4, 2.2.A.3:

Delete: Item 3. in its entirety

Insert: “3. YKK model ‘50D’ entrance door”

Page 4, 2.2.B.3:

Delete: “2 inches”

Insert: “1-3/4 inches”

Page 7, 2.8:

Insert:

- “B. Aluminum doors shall be thermally-broken extruded aluminum, pre-glazed, single acting, hinged doors, wide stile-and-rail type. Subject to compliance with the requirements specified herein, products may be incorporated in the work include the following:
- a. Kawneer model “500 Insulclad” door
 - b. EFCO model “D502 (TS) ThermaStile” door
 - c. YKK model “50XT Megatherm” door”

PART 3 – DRAWINGS

None

PART 4 – ATTACHMENTS

1. Pre-Bid Walk Through Sign-in Sheet 9.16.26

END OF ADDENDUM NO. 1

Sign-in Sheet

Meeting Type: Pre-Bid Walk Through

Date: 09/16/2026

Name	Contractor	Email	Telephone
Tim Carbone	National Glass	tim@nationalglassworks.com	same 2
Also David	cc		508-7520805
James Soffen	Campora Construction	james@campora.cc.com	413-204-3354