

January 30, 2023

To All Bidders:

Subject: <u>7962-M3 Overhead Door Replacement WFD/WFD</u>

# **ADDENDUM NO. 1**

To Whom It May Concern:

With reference to our proposal request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

## Pre-Bid Walk Thru-

February 2, 2023. 180 Southbridge St, Worcester, MA 01608 @ 10:00 a.m.

## Question 1

Both 2" and 3" track are specified. You have 2" track now and 3" track requires more clearance (which is unavailable at this site)

Answer: 2" Tracks are to be used.

#### Question 2

Spec calls for transferring sensing edge from existing door to new door. I don't think there is a sensing edge on the existing door

Answer: Provide sensing edge.

## Question 3

Spec calls for tempered  $\frac{1}{2}$ " insulated glass. Glass can be  $\frac{1}{2}$ " or insulated; not both **Answer: Provide insulated glass.** 

## - Question 4

Spec calls for lintel brush seal. This is typically used on rolling steel doors, not sectional doors **Answer: Remove lintel brush seal.** 

(more)





Question 5

Spec calls for a lock. A lock is not recommended on a door that has an electric operator **Answer: Remove interior locking device.** 

Question 6

It looks like existing components at the rear of the new horizontal track will be moved to allow for the torsion spring to be rear mounted

Answer: Provide for rear mounted torsion spring, provide bracing as needed.

Proposers are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Maureen McKeon Assistant Purchasing Director