



December 30, 2021

To All Bidders:

Subject: **Bid No. CR-7737-W2, Maintenance – Generators / WPS & City**

ADDENDUM NO. 2

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **BID DUE DATE HAS BEEN EXTENDED TO WEDNESDAY, JANUARY 19, 2022 AT 10:00 AM**
- *Please see below general bid clarifications including questions from bidders and responses from City:*
 - 6. City View: Kohler 80ROZ 500kw Kohler model 80ROZ should have a kw of 80 as is reflected in model name. If the kw is 500 then the generator is not an 80ROZ
Model#80ROZ91
 - 7. Columbus: D100FPP4 55kw Same as above. Is the unit a diesel, and if so do you have engine info.
Manufacturer - Katolight
Engine Make Perkins
Engine Model #YB 35012
 - 11. Gates Lane: Cummins 200kw model info is incorrect. Engine is prob an NT855
Model # UC1274H1
 - 14. Nelson: Caterpillar 200kw all older cats were SR4. Engine info is essential. Probably a 3208 engine
Model# D200-2



18. Quinsigamond: Cummins 140kw model info is incorrect. Engine is prob GTA8.3

Model# 6855

22. Wawecus: Ready Power 25kw not a manufacturer. Unit is prob a Generac, or was made by Generac and private labeled

Ready Power is the name on the tag

Model# CD277A18

26. Tech HS: Stamford 500kw not a generator manufacturer. Make generator back ends. Need gen make & model & gen make & model

Stamford

HC15304D12

9. Fanning Empire 2000DDGN , Not a well know brand.

Need additional info -

Serial # 479-11

Cummins Engine # NT-855-G

Fuel Type - Diesel

120/208 Volts 3phase

200 KW

10. Forrest Superior 125R, Nat gas or diesel?

Natural Gas

Cummins Engine

13. Hiatt CPI 45D8T, D8T indicates that the unit is a diesel 8 cylinder Turbo and if so it would be much more that a 45kw

Jacob Hiatt's unit is out of commission.

The bid is asking for an infrared inspection of the ATS units. A single generator can have more than one ATS associated with it. Do you know how many ATS units are to be serviced?

27 ATS unit

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro
Purchasing Director