



June 23, 2022

To All Bidders:

Subject: **Bid No. CR-7833-W2, Filter & Belt Maintenance / WPS**

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **Please see below general bid clarifications:**
 - The ionization units are MERV 13's and the RTU's are typically the MERV 8's.
 - Some of WPS' newer schools (South, North, Nelson Place) have MERV 13's in the RTU's
 - WPS is currently working on upgrades to some roof top equipment to MERV 13 over the next several months. WPS will work with the contracted vendor to address any increases to the 13's on selected pieces of equipment at some point in the future.
 - Bidders shall bid according to the list included with this bid.
 - All work to be done on the second shift so as not to impact the learning environment.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro
Purchasing Director