

Purchasing Director

January 26, 2023
To All Bidders:
Subject: Bid No. CR-7961-W3, Insertion Valves & Tapping Services / DPWP
ADDENDUM NO. 1 To Whom It May Concern:
With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.
The City standard is an open right valve (clockwise).
All valves, including insertion valves, shall be fitted with a standard 2-inch square operating nut and shall open right (clockwise).
Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.
Very truly yours,