



The City of **WORCESTER**

Administration & Finance – Purchasing Division
Christopher J. Gagliastro, MCPPO – Purchasing Director
455 Main Street, Room 201, Worcester, MA 01608
P | 508-799-1220
purchasing@worcesterma.gov

July 28, 2023

To All Bidders:

Subject: **CR-8048-W4 Chemicals, Misc. – Filtration Plant / DPWP**

ADDENDUM NO. 2

To Whom It May Concern:

With reference to our proposal request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **See below for clarification regarding a bidder's question.**

Question: “I have a question regarding item 3- Pebble lime on the Chemicals, Misc. bid, please. Can I trouble you for a copy of the coa and spec for the pebble lime?”

Answer: The size of the quick lime is in the bid spec in the bid document. The lime is required to be > or = to 90 percent calcium oxide.

Proposers are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Maureen McKeon
Assistant Purchasing Director