



# The City of **WORCESTER**

Administration & Finance – Purchasing Division  
Christopher J. Gagliastro, MCPPO – Purchasing Director  
455 Main Street, Room 201, Worcester, MA 01608  
P | 508-799-1220  
[purchasing@worcesterma.gov](mailto:purchasing@worcesterma.gov)

September 30, 2024

To All Bidders:

Subject: **Bid No. CR-8285-W5, Air Filters & Belts / WPS**

## **ADDENDUM NO. 2**

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **PLEASE SEE ATTACHED QUESTIONS RECEIVED AND RESPONSES FROM CITY**

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions, and specifications remain unchanged.

Very truly yours,

Christopher J. Gagliastro  
Purchasing Director

- Will the total pricing be based on the unit quantity or filter quantity?  
*Total price based on all items (filters and belts combined)*

On the DOHERTY HIGH HAAKON Filters, filter size of 24 x 24 x 12 and other subsequent 12" thick filters, what is the style of the filter? Are they the rigid cells or the ASHRAE style? *Rigid with header*

On the North High Filters, filter size of 20 x 20 x 12 and other subsequent 12" thick filters, what is the style of the filter? Are they the rigid cells or the ASHRAE style? *Merv 13, 12" thick Rigid cell filters*

How many 3-BX-90 Belts are needed at Thorndyke St. School? *1 annually*

Can you please provide the MERV rating for the VirusDoc and RAF filters? *The RAF and VirusDoc filters are Merv13.*

What type of filters are the following:

DOHERTY HIGH HAAKON Filters						
UNIT	TYPE	MERV RATING	SIZE (L" x H" x D")	QUANTIT Y	UNIT PRICE	TOTAL PRI
RTU-1	Pre	8	24 x 24 x 2	6		
		8	24 x 12 x 2	2		
	Post	13	24 x 24 x 12	6		
		13	24 x 12 x 12	2		
	Retur	8	24 x 24 x 2	6		

*These filters are Merv 13, Rigid cell filters with a header.*

Is the highlighted belt # is BX38 without 1?

A43	1	
1BX38	1	
BX50	1	

*No, this is the correct number*

Are the highlighted size below correct?

3VX1000	4	
3VX1060	2	
BUX1320	2	
A51	1	
4L460R	1	
AX41	3	
AX41	3	

4L380	1		
AP31	1		
AM1	2		

3-BX-90			

*The first highlighted item is BVX1320, the others are correct.*

What type of filter MERV14 highlighted below? Are there Mini-pleat MERV14 with plastic frames?

DOHERTY HIGH DAIKIN Filters						
UNIT	TYPE	MERV RATING	SIZE (L" x H" x D")	QUANTITY	UNIT PRICE	TOTAL
AHU-1	Pre	8	24 x 24 x 2	2		
		8	24 x 20 x 2	1		
	Post	14	24 x 24 x 4	2		
		14	24 x 20 x 4	1		
	Return	8	24 x 24 x 2	2		
		8	24 x 20 x 2	1		

					TOTAL PRICE	
RTU-9	Pre	8	20 x 24 x 2	6		
		14	20 x 24 x 4	6		
	Post	8	20 x 20 x 2	6		
		14	20 x 20 x 4	6		
	Return	8	20 x 24 x 2	9		
		8	20 x 20 x 2	3		
	Pre	8	16 x 25 x 2	16		

*These are pre-filters.*

Are the sizes under the following pleated filters MERV 8 or unit filters?

**DOHERTY HIGH DAIKIN Filters "A"**

**DOHERTY HIGH DAIKIN Filters "B"**

**DOHERTY HIGH DAIKIN Filters "C"**

**DOHERTY HIGH DAIKIN Filters "D"**

**DOHERTY HIGH DAIKIN Filters "E"**

*Yes, all are MERV 8*

**DAIKIN AHU Filters**

*Please consult the bid package, the majority are MERV8 with the exception of the Post, which are MERV14*