

December 31, 2024

To All Bidders:

Subject: Bid No. CR-8338-M5 – Maintenance & Repair – Generators / WPS & City

ADDENDUM NO. 4

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

Questions received by the City and answers below:

- 1) We wanted to confirm that there are 25 generators that need to be serviced from the wps main list and not 26. *There are 26 generators including the new one at Doherty Memorial High School.*
- 2) We wanted to confirm the size of the generator at city view given it was posted on the gen spec sheet as a Kohler 80ROZ91 but posted as a 500kw which does not match as far as our records indicate. The generator at CityView is a Kohler Generator with 500 kW, the incorrect model number was entered into the spreadsheet; the correct Model is 80ROZJ91.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Stephen R. McDonald Assistant Purchasing Director