Inspection and Testing Certificate

Presented To

The City of Worcester/ WPS

For

Worcester East Middle School

420 Grafton St Worcester, Massachusetts 01608 United States

This site has been inspected and tested in compliance with applicable standards.

Completed Monday, January 09, 2023

Test Session: 09 Jan 2023 17:08

ACCEPTED BY

The City of Worcester/ WPS
455 Main Street
Room 201
Worcester, Massachusetts 01608
United States

TESTED BY

Nick Akoumianakis Northeast Integrated Systems 17 Lincoln Street Malden MA 02148 United States

INSPECTION STATUS

Attention needed

One or more Deficiencies have been identified, system may respond if needed



Inspection Summary

Building Information

PROPERTY Worcester East Middle School CONTACT

ADDRESS 420 Grafton St PHONE

CITY/STATE/ZIP Worcester, Massachusetts 01608 MOBILE

COUNTRY United States EMAIL

Inspector Information

COMPANY Northeast Integrated Systems CONTACT Nick Akoumianakis

ADDRESS 17 Lincoln Street

Malden MA 02148 PHONE +1 781-780-1930

LICENSE NUMBER

COUNTRY United States EMAIL nick.akoumianakis@nefs.us

Testing Summary

| EQUIPMENT TYPE | TOTAL | TESTED | PASSED | FAILED |
|----------------------------------|-------|----------|----------|---------|
| Alarm Notification Appliance | 19 | 19(100%) | 19(100%) | 0(0%) |
| Fire Control Panel | 1 | 1(100%) | 0(0%) | 1(100%) |
| Initiating Device | 93 | 93(100%) | 79(85%) | 14(15%) |
| Power Supplies | 2 | 2(100%) | 1(50%) | 1(50%) |
| Public Emergency Alarm Reporting | 1 | 1(100%) | 1(100%) | 0(0%) |

Certification

ACCEPTED BY

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, January 09, 2023

01/09/2023 TESTED BY

Nick Akoumianakis

01/09/2023

Building Representative Technician

System Details

Control Units

MANUFACTURER SECUTRON DESCRIPTION 1st Administration Office

MODEL MR-2605 S/W VERSION
SERIAL NUMBER MR-2605 LAST UPDATE
INSTALL DATE 11/06/2020 S/W LOCATION

Secondary Power

TYPE Battery - Sealed Lead-acid DESCRIPTION 1st Administration Office

NOMINAL VOLTAGE 12 LOAD VOLTAGE

AMP HOURS 7.5 STANDBY HOURS

ALARM MINUTES BATTERY LOCATION Inside FACU

CHARGER VOLTAGE

Open Corrective Action & Solution Summary

The following 16 corrective action(s) remain open following the system inspection, testing or maintenance activities

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION |
|--------------------------|---|---|
| Fire Alarm Control Panel | FACU | 1st Administration Office |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 NAC 1 not supervised. EOL @ facu SECUTRON MR-2605 |
| Manual Pull Station | Z2 | HALL O/S ELEVATOR BASEMENT |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Lock Damaged |
| Heat Detector | Z2 | BOYS LOCKER ROOM STORAGE BASEMENT |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Failed Operation |
| Heat Detector | Z2 | GIRLS LOCKER ROOM BASEMENT |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Device Missing |
| Heat Detector | Z3 | PRINCIPALS OFFICE 1ST FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Device Missing |
| Heat Detector | Z3 | ADMINISTRATION CONFERENCE ROOM 1ST FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Failed Operation |
| Manual Pull Station | Z3 | HALL O/S ROOM 112 1ST FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Glued to wall. Cannot open |

Northeast Integrated Systems Page 4 of 18

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION |
|----------------------------|---|--|
| Manual Pull Station | Z3 | HALL O/S ROOM 107 1ST FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Lock Damaged |
| Manual Pull Station | Z4 | HALL O/S ROOM 207 2ND FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Lock Damaged |
| Heat Detector | Z4 | HALL O/S ROOM 214a 2ND FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Lock Damaged |
| Heat Detector | Z4 | HALL O/S ROOM 221 2ND FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Device Missing |
| Manual Pull Station | Z5 | HALL O/S ROOM 307 3RD FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Lock damaged |
| Manual Pull Station | Z5 | HALL O/S ROOM 313 3RD FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Key broken inside lock. Cannot test without replacing |
| Battery - Sealed Lead-acid | FACU Batteries | 1st Administration Office |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Date Expired Replace SigmasTek SP12-7.5 |
| Heat Detector | Z5 | BOYS ROOM 3RD FLOOR |
| | Created By: | Nick Akoumianakis |

Northeast Integrated Systems

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION |
|----------------|---|---|
| | Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | 01/09/2023 Failed Heat Test |
| Heat Detector | Z3 | ADMINISTRATION PSYCHOLOGIST ROOM 1ST FLOOR |
| | Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model: | Nick Akoumianakis 01/09/2023 Improperly mounted Properly Mount |

Testing Details

Alarm Notification Appliance

| Passed | | | | |
|----------------|---------|---|---------------------------|---------------------|
| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
| Horn | - | BOILER ROOM BASEMENT | Manual | 1/9/2023 5:20:14 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Horn | - | CAFETERIA BASEMENT | Manual | 1/9/2023 5:20:20 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S B1 BASEMENT | Manual | 1/9/2023 5:20:22 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S B17 BASEMENT | Manual | 1/9/2023 5:20:24 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL ACROSS FROM ELEVATOR BASEMENT | Manual | 1/9/2023 5:20:25 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 103 1ST FLOOR | Manual | 1/9/2023 5:20:28 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 107 1ST FLOOR | Manual | 1/9/2023 5:20:29 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 112 1ST FLOOR | Manual | 1/9/2023 5:20:31 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 117 1ST FLOOR | Manual | 1/9/2023 5:20:33 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 217 2ND FLOOR | Manual | 1/9/2023 5:20:34 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 214A 2ND FLOOR | Manual | 1/9/2023 5:20:36 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 207 2ND FLOOR | Manual | 1/9/2023 5:20:38 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 203 2ND FLOOR | Manual | 1/9/2023 5:20:39 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 307 3RD FLOOR | Manual | 1/9/2023 5:20:41 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn / Strobe | - | SCIENCE LAB 3RD FLOOR | Manual | 1/9/2023 5:20:42 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn / Strobe | - | SCIENCE LAB STORAGE 3RD FLOOR | Manual | 1/9/2023 5:20:44 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |

Northeast Integrated Systems Page 7 of 18

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|----------------|---------|---|---------------------------|---------------------|
| Horn / Strobe | - | ROOM 309 3RD FLOOR | Manual | 1/9/2023 5:20:46 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 217 3RD FLOOR | Manual | 1/9/2023 5:20:48 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Horn | - | HALL O/S ROOM 213 3RD FLOOR | Manual | 1/9/2023 5:20:50 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |

Fire Control Panel

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---|---------|---------------------------|-----------------|---------------------|
| Fire Alarm Control Panel | FACU | 1st Administration Office | Manual | 1/9/2023 5:29:28 PM |
| Control unit visual Inspection | Passed | Manufacturer | SECUTRON | |
| Control unit functional Inspection | Passed | Model | MR-2605 | |
| Lamps/LEDs/LCDs visual Inspection | Passed | Serial Number | MR-2605 | |
| Lamps/LEDs/LCDs functional Inspection | Passed | Visual Inspection | Failed (Manual) | |
| Fuses visual Inspection | Passed | Functional Inspection | Failed | |
| Fuses functional Inspection | Passed | | | |
| Trouble Signals visual Inspection | Passed | | | |
| Trouble Signals functional Inspection | Passed | | | |
| Disconnect Switches visual Inspection | Passed | | | |
| Disconnect Switches functional Inspection | Passed | | | |
| Ground-fault monitoring visual Inspection | Passed | | | |
| Ground-fault monitoring functional Inspection | Passed | | | |
| Supervision visual Inspection | Passed | | | |
| Supervision functional Inspection | Passed | | | |
| Local annunciator visual Inspection | Passed | | | |
| Local annunciator functional Inspection | Passed | | | |
| Remote annunciators visual Inspection | Passed | | | |
| Remote annunciators functional Inspection | Passed | | | |
| Remote power panels visual Inspection | Passed | | | |
| Remote power panels functional Inspection | Passed | | | |
| Initiating Daviso | | | | |

Initiating Device

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|---|---------------------------|---------------------|
| Manual Pull Station | Z5 | HALL O/S ROOM 317 3RD FLOOR | Manual | 1/9/2023 5:58:32 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z5 | SCIENCE ROOM 309 3RD FLOOR | Manual | 1/9/2023 6:04:08 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z5 | SCIENCE ROOM 309 3RD FLOOR | Manual | 1/9/2023 6:04:32 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z5 | ROOM 355 3RD FLOOR | Manual | 1/9/2023 6:10:47 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|------------|--|------------------------|------------------------|
| Equil MENT TITE | ABBREES | Visual Inspection | Passed (Manual) | D/(TE/TIME |
| | | Functional Inspection | Passed | |
| Heat Detector | Z5 | 3rd BATHROOM 306 3RD FLOOR | Manual | 1/9/2023 6:12:06 PM |
| | | Visual Inspection | Passed (Manual) | |
| | 7.5 | Functional Inspection | Passed | 4/0/0000 0 40 00 554 |
| Heat Detector | Z5 | STORAGE ROOM 3RD FLOOR | Manual | 1/9/2023 6:12:38 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | Z5 | HALL O/S ROOM 303 3RD FLOOR | Manual | 1/9/2023 6:18:01 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z 5 | GIRLS ROOM 3RD FLOOR | Manual | 1/9/2023 6:19:28 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | Z4 | HALL O/S ROOM 217 2ND FLOOR | Manual | 1/9/2023 6:22:35 PM |
| | | Visual Inspection | Passed (Manual) | |
| Heat Detector | 74 | Functional Inspection GIRLS ROOM 2ND FLOOR | Passed | 1/0/2022 6:24:20 DM |
| near Detector | Z4 | | Manual Passed (Manual) | 1/9/2023 6:24:26 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z4 | ROOM 221 2ND FLOOR | Manual | 1/9/2023 6:29:32 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z4 | RESTROOM 2ND FLOOR | Manual | 1/9/2023 6:29:57 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z4 | ROOM 220 2ND FLOOR | Manual | 1/9/2023 6:32:30 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z4 | ROOM 255 2ND FLOOR | Manual | 1/9/2023 6:40:37 PM |
| Tieat Detector | 24 | Visual Inspection | Passed (Manual) | 1/9/2023 0.40.37 1 W |
| | | Functional Inspection | Passed | |
| Heat Detector | Z4 | ROOM 218 2ND FLOOR | Manual | 1/9/2023 6:42:18 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z4 | STAFF RESTROOM 2ND FLOOR | Manual | 1/9/2023 6:46:01 PM |
| | | Visual Inspection | Passed (Manual) | |
| Heat Data star | 7.4 | Functional Inspection | Passed | 4/0/0000 0 40 04 DN4 |
| Heat Detector | Z4 | ROOM 219 2ND FLOOR Visual Inspection | Manual Passed (Manual) | 1/9/2023 6:46:31 PM |
| | | Functional Inspection | Passed (Manual) | |
| Heat Detector | Z4 | BOYS ROOM 2ND FLOOR | Manual | 1/9/2023 6:48:16 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | Z4 | HALL O/S ROOM 203 2ND FLOOR | Manual | 1/9/2023 6:50:57 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | 1/0/0005 |
| Manual Pull Station | Z3 | HALL O/S ROOM 103 1ST FLOOR | Manual (Manual) | 1/9/2023 6:51:24 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | TEACHERS RESTROOM 1ST FLOOR | | 1/9/2023 6:53:09 PM |
| Jul Dollotoi | | Visual Inspection | Passed (Manual) | ./0/2020 0.00.00 1 101 |
| | | Functional Inspection | Passed | |
| Heat Detector | Z3 | BOYS ROOM 1ST FLOOR | Manual | 1/9/2023 6:59:20 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Northeast Integrated Systems Page 9 of 18

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|----------------|---------|---|---------------------------|----------------------|
| Smoke Detector | Z3 | MWR RESTROOM 1ST FLOOR | Manual | 1/9/2023 7:01:15 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | TEACHERS LOUNGE 1ST FLOOR | Manual | 1/9/2023 7:02:37 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | TEACHERS LOUNGE 1ST FLOOR | Manual | 1/9/2023 7:02:51 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z3 | TEACHERS LOUNGE CLOSET 1ST FLOOR | Manual | 1/9/2023 7:03:35 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | WORK ROOM 1ST FLOOR | Manual | 1/9/2023 7:04:40 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | WORK ROOM 2 1ST FLOOR | Manual | 1/9/2023 7:05:38 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z3 | ROOM 1ST FLOOR | Manual | 1/9/2023 7:07:21 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | RESTROOM 1ST FLOOR | Manual | 1/9/2023 7:07:42 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | STORAGE SODA CLOSET 1ST FLOOR | Manual | 1/9/2023 7:08:04 PM |
| | | Visual Inspection | Passed (Manual) | |
| Heat Detector | Z3 | Functional Inspection SCHOOL ADJ COUNSELOR BATHROOM 1ST FLOOR | Passed Manual | 1/9/2023 7:10:16 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | SCHOOL ADJ COUNSELOR ROOM 1ST FLOOR | Manual | 1/9/2023 7:10:23 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z3 | ADMINISTRATION COAT ROOM 1ST FLOOR | Manual | 1/9/2023 7:13:09 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | ADMINISTRATION O/S COAT ROOM 1ST FLOOR | Manual | 1/9/2023 7:13:30 PM |
| | | Visual Inspection | Passed (Manual) | |
| Hart Date 1 | 70 | Functional Inspection KITCHEN BEHIND MAIN OFFICE 1ST | Passed | 4/0/0000 7 47 00 514 |
| Heat Detector | Z3 | FLOOR Visual Inspection | Manual Passed (Manual) | 1/9/2023 7:17:06 PM |
| | | Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | ADMINISTRATION FILE ROOM 1ST FLOOR | Manual | 1/9/2023 7:18:14 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z3 | ADMINISTRATION OFFICE 1ST FLOOR | Manual | 1/9/2023 7:18:55 PM |
| | | Visual Inspection | Passed (Manual) | |
| Heat Date | 70 | Functional Inspection ADMINISTRATION OFFICE@FACU | Passed | 4/0/0000 7 40 00 7 |
| Heat Detector | Z3 | 1ST FLOOR | Manual Paggad (Manual) | 1/9/2023 7:19:08 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |

Northeast Integrated Systems Page 10 of 18

| Matheway | FOURMENT TYPE | ADDDEEC | DESCRIPTION | METHOD | DATE/TIME |
|--|-----------------------|-------------|----------------------------|-----------------|-----------------------|
| FLOOR | | | | | |
| Heat Detector | near Detector | ZS | | iviariual | 1/9/2023 7:29:42 PIVI |
| Heat Detector Z3 | | | | , | |
| SISTELOOR | Hard Date 1 | 70 | · | | 4/0/0000 7 00 04 50 |
| Heat Detector | Heat Detector | Z3 | | Manual | 1/9/2023 7:30:01 PM |
| PRINCIPALS OFFICE STORAGE 1ST Manual 1/9/2023 7.30.38 PM PLOOR | | | Visual Inspection | Passed (Manual) | |
| PLOOR | | | • | | |
| Functional Inspection | Heat Detector | Z3 | | Manual | 1/9/2023 7:30:38 PM |
| Heat Detector | | | Visual Inspection | Passed (Manual) | |
| ROOM 15T FLOOR | | | | Passed | |
| Visual Inspection Passed (Manual) Passed (| Heat Detector | Z3 | | Manual | 1/9/2023 7:31:50 PM |
| ADMINISTRATION CONFERENCE Manual 1/8/2023 7.36:00 PM | | | | Passed (Manual) | |
| BATHROOM ROOM IST FLOOR | | | Functional Inspection | Passed | |
| Functional Inspection | Heat Detector | Z3 | | Manual | 1/9/2023 7:36:00 PM |
| Real Detector | | | · | | |
| Visual Inspection Passed (Manual) Passed (Manual) Passed | H. A.D. A. | 70 | · | | 4/0/0000 7 // 07 7 |
| Functional Inspection | Heat Detector | Ζ3 | | | 1/9/2023 7:41:05 PM |
| Heat Detector | | | | , | |
| Visual Inspection Passed (Manual) Passed | Heat Detector | Z3 | · | | 1/9/2023 7:41:34 PM |
| Functional Inspection | | | | | |
| Visual Inspection Passed (Manual) Functional Inspection Passed Pa | | | · | | |
| Heat Detector Z3 ROOM 99 1ST FLOOR Manual 1/9/2023 7:42:09 PM | Heat Detector | Z3 | ROOM 99 1ST FLOOR | Manual | 1/9/2023 7:42:01 PM |
| Heat Detector | | | | | |
| Visual Inspection Passed (Manual) Functional Inspection Passed (Manual) Passed | | | · | | |
| Functional Inspection | Heat Detector | Z3 | | | 1/9/2023 7:42:09 PM |
| Heat Detector | | | · | , | |
| Visual Inspection Passed (Manual) Functional Inspection Passed | Heat Detector | Z3 | · | | 1/9/2023 7·42·22 PM |
| Functional Inspection Passed | | | | | |
| Visual Inspection Passed (Manual) Functional Inspection Passed Pa | | | • | , | |
| Manual Pull Station Z2 | Heat Detector | Z3 | HALL O/S ROOM 99 1ST FLOOR | Manual | 1/9/2023 7:45:49 PM |
| Manual Pull Station Z2 HALL O/S ROOM B3 BASEMENT Manual 1/9/2023 7:48:08 PM Visual Inspection Passed (Manual) Passed Manual Pull Station Z2 HALL O/S B6 BASEMENT Manual 1/9/2023 7:51:08 PM Manual Pull Station Z2 HALL O/S B6 BASEMENT Manual 1/9/2023 7:51:08 PM Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:17 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Passed Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:27 PM Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:27 PM Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Heat Detector Z2 <t< td=""><td></td><td></td><td>Visual Inspection</td><td>Passed (Manual)</td><td></td></t<> | | | Visual Inspection | Passed (Manual) | |
| Visual Inspection | | | Functional Inspection | Passed | |
| Functional Inspection Passed | Manual Pull Station | Z2 | | | 1/9/2023 7:48:08 PM |
| Manual Pull Station Z2 HALL O/S B6 BASEMENT Manual 1/9/2023 7:51:08 PM Visual Inspection Passed (Manual) Functional Inspection Passed (Manual) Passed Passed (Manual) Passed Heat Detector Z2 KITCHEN BASEMENT Manual | | | · | | |
| Visual Inspection | Manual Pull Station | 72 | | | 1/0/2023 7·51·00 DM |
| Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:17 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed (Manual) Passed (Manua | ivianuai Fuli Station | LL | | | 1/8/2023 7.31.00 PIVI |
| Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:17 PM Extremely Dirty Visual Inspection Passed (Manual) | | | | | |
| Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:27 PM Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed (Manual) Functional Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | Heat Detector | Z2 | | Manual | 1/9/2023 7:57:17 PM |
| Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:27 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed (Manual) Functional Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | | Comment: | | | |
| Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:57:27 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | | | • | , | |
| Comment: Extremely Dirty Visual Inspection Functional Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | Lloot Data star | 70 | | | 1/0/2022 7:57:27 554 |
| Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | near Defector | | | ivianual | 1/9/2023 /:5/:2/ PM |
| Heat Detector Z2 KITCHEN BASEMENT Manual 1/9/2023 7:58:02 PM Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) Functional Inspection Passed (Manual) | | | | Passed (Manual) | |
| Comment: Extremely Dirty Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | | | | , | |
| Visual Inspection Passed (Manual) Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | Heat Detector | Z2 | | Manual | 1/9/2023 7:58:02 PM |
| Functional Inspection Passed Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | | Comment: | | D1/44 | |
| Heat Detector Z2 KITCHEN STORAGE BASEMENT Manual 1/9/2023 8:02:02 PM Visual Inspection Passed (Manual) | | | • | , | |
| Visual Inspection Passed (Manual) | Heat Detector | Z2 | | | 1/9/2023 8:02·02 PM |
| | | | | | |
| | | | | , , | |

Northeast Integrated Systems Page 11 of 18

| FOUIDMENT TYPE | ADDDEAG | DECORIDATION | METHOD | DATE/THAE |
|-------------------------------|---------------|---|------------------------|----------------------------------|
| EQUIPMENT TYPE Heat Detector | ADDRESS Z2 | DESCRIPTION KITCHEN STORAGE BASEMENT | METHOD Manual | DATE/TIME 1/9/2023 8:02:11 PM |
| Heat Detector | LL | Visual Inspection | Passed (Manual) | 1/3/2023 0.02.11 PIVI |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | KITCHEN STORAGE BASEMENT | Manual | 1/9/2023 8:02:17 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | Manual | 1/9/2023 8:09:59 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | Manual | 1/9/2023 8:10:05 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | Manual | 1/9/2023 8:11:01 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | Manual | 1/9/2023 8:16:53 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | Manual | 1/9/2023 8:17:01 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | Manual | 1/9/2023 8:19:36 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection BOYS LOCKER ROOM/WEIGHT | Passed | |
| Heat Detector | Z2 | ROOM BASEMENT | Manual | 1/9/2023 8:19:38 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | Z2 | HALL O/S B17 BASEMENT | Manual | 1/9/2023 8:22:14 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z2 | ROOM NEXT TO BOYS RM | Manual | 1/9/2023 8:24:22 PM |
| | | BASEMENT | December 1 (Manual) | |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z2 | BOYS ROOM BASEMENT | Manual | 1/9/2023 8:25:45 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | ROOM B6B BASEMENT | Manual | 1/9/2023 8:26:45 PM |
| | | Visual Inspection | Passed (Manual) | |
| Host Dotestor | Z1 | Functional Inspection ELECTRICAL ROOM SUB- | Passed | 1/0/2022 0-24-42 DM |
| Heat Detector | 21 | BASEMENT | Manual | 1/9/2023 8:31:12 PM |
| | | Visual Inspection | Passed (Manual) | |
| Heat Detector | Z2 | Functional Inspection CUSTODIANS ROOM BASEMENT | Passed | 1/0/2022 0-24-40 DM |
| Heat Detector | LL | Visual Inspection | Manual Passed (Manual) | 1/9/2023 8:31:19 PM |
| | | Functional Inspection | Passed (Maridar) | |
| Heat Detector | Z2 | GIRLS ROOM BASEMENT | Manual | 1/9/2023 8:32:29 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z1 | BOILER ROOM SUB-BASEMENT | Manual | 1/9/2023 8:35:17 PM |
| | | Visual Inspection | Passed (Manual) Passed | |
| Heat Detector | Z1 | Functional Inspection BOILER ROOM SUB-BASEMENT | Manual | 1/9/2023 8:35:18 PM |
| rical Delector | 21 | DOILLIN ROOM SUB-DASEMENT | iviariuai | 1/3/2023 0.33. 10 PIVI |

Northeast Integrated Systems

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|---|----------------------------|---------------------|
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z1 | BOILER ROOM SUB-BASEMENT | Manual | 1/9/2023 8:35:20 PM |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector | Z2 | GIRLS LOCKER ROOM BASEMENT | Manual | 1/9/2023 8:40:42 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z2 | GIRLS LOCKER ROOM BASEMENT | Manual | 1/9/2023 8:41:54 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z2 | GIRLS LOCKER ROOM BASEMENT | Manual | 1/9/2023 8:42:19 PM |
| | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector | Z2 | ROOM B52 BASEMENT | Manual | 1/9/2023 8:43:19 PM |
| Failed | | Visual Inspection Functional Inspection | Passed (Manual) Passed | |
| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
| Manual Pull Station | Z5 | HALL O/S ROOM 313 3RD FLOOR | Manual | 1/9/2023 6:01:10 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Manual Pull Station | Z5 | HALL O/S ROOM 307 3RD FLOOR | Manual | 1/9/2023 6:08:37 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Heat Detector | Z5 | BOYS ROOM 3RD FLOOR | Manual | 1/9/2023 6:15:00 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Heat Detector | Z4 | HALL O/S ROOM 221 2ND FLOOR | Manual | 1/9/2023 6:27:08 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Heat Detector | Z4 | HALL O/S ROOM 214a 2ND FLOOR | Manual 1/9/2023 6:36:11 PM | |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Manual Pull Station | Z4 | HALL O/S ROOM 207 2ND FLOOR | Manual | 1/9/2023 6:38:05 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Manual Pull Station | Z3 | HALL O/S ROOM 107 1ST FLOOR | Manual | 1/9/2023 6:55:03 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Manual Pull Station | Z3 | HALL O/S ROOM 112 1ST FLOOR | Manual | 1/9/2023 6:57:10 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Heat Detector | Z3 | ADMINISTRATION PSYCHOLOGIST ROOM 1ST FLOOR | Manual | 1/9/2023 7:14:55 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Heat Detector | Z3 | PRINCIPALS OFFICE 1ST FLOOR | Manual | 1/9/2023 7:29:05 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Heat Detector | Z3 | ADMINISTRATION CONFERENCE ROOM 1ST FLOOR | Manual | 1/9/2023 7:33:53 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Manual Pull Station | Z2 | HALL O/S ELEVATOR BASEMENT | Manual | 1/9/2023 8:08:39 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) | |

Northeast Integrated Systems Page 13 of 18

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|----------------|---------|---|---------------------------|---------------------|
| Heat Detector | Z2 | BOYS LOCKER ROOM STORAGE BASEMENT | Manual | 1/9/2023 8:13:14 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |
| Heat Detector | Z2 | GIRLS LOCKER ROOM BASEMENT | Manual | 1/9/2023 8:39:28 PM |
| | | Visual Inspection Functional Inspection | Failed (Manual) Failed | |

Power Supplies

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--|----------------|---------------------------|-----------------|---------------------|
| Battery - Sealed Lead-acid | FACU Batteries | 1st Administration Office | Manual | 1/9/2023 5:23:39 PM |
| | Comment: | 2x 7.5ah | | |
| Battery condition visual Inspection | Passed | Manufacturer | SigmasTek | |
| Battery condition functional Inspection | Passed | Model | SP12-7.5 | |
| Load voltage visual Inspection | Passed | Visual Inspection | Failed (Manual) | |
| Load voltage functional Inspection | Passed | Functional Inspection | Failed | |
| Discharge test visual Inspection | Passed | Amp Hours | 7.5 | |
| Discharge test functional Inspection | Passed | Battery Location | Inside FACU | |
| Charger test visual Inspection | Passed | Battery Type | SLA | |
| Charger test functional Inspection | Passed | Nominal Voltage | 12 | |
| Remote panel batteries visual Inspection | Passed | Туре | SLA | |
| Remote panel batteries functional Inspection | Passed | | | |
| | | | | |

Public Emergency Alarm Reporting

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|----------------|-----------|------------------------------------|-----------------|---------------------|
| Master Box | RMB #1022 | 1st Administration Conference Room | n Manual | 1/9/2023 5:35:35 PM |
| | | Manufacturer | AES | |
| | | Model | 7750-F-8 | |
| | | Visual Inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Northeast Integrated Systems

Device/Equipment Details

| Alarm Notific | ation Appliance | | | | |
|---|---|--------------|---------|---------|--------------|
| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
| Horn | | | | | |
| | BOILER ROOM BASEMENT | | | | 11/07/2022 |
| | CAFETERIA BASEMENT | | | | 11/07/2022 |
| | HALL O/S B1 BASEMENT | | | | 11/07/2022 |
| | HALL O/S B17 BASEMENT | | | | 11/07/2022 |
| | HALL ACROSS FROM ELEVATOR BASEMENT | | | | 11/07/2022 |
| | HALL O/S ROOM 103 1ST FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 107 1ST FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 112 1ST FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 117 1ST FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 217 2ND FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 214A 2ND FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 207 2ND FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 203 2ND FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 307 3RD FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 217 3RD FLOOR | | | | 11/07/2022 |
| | HALL O/S ROOM 213 3RD FLOOR | | | | 11/07/2022 |
| Horn / Strobe | | | | | |
| | SCIENCE LAB 3RD FLOOR | | | | 11/07/2022 |
| | SCIENCE LAB STORAGE 3RD FLOOR | | | | 11/07/2022 |
| | ROOM 309 3RD FLOOR | | | | 11/07/2022 |
| ire Control I | Panel | | | | |
| DDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
| ire Alarm Contro | ol Panel | | | | |
| ACU | 1st Administration Office | SECUTRON | MR-2605 | MR-2605 | 11/07/2020 |
| nitiating Dev | rice | | | | |
| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
| leat Detector | | | | | |
| 11 | BOILER ROOM SUB- BASEMENT | | | | 11/07/2022 |
| 1 | BOILER ROOM SUB- BASEMENT | | | | 11/07/2022 |
| .1 | BOILER ROOM SUB- | | | | 11/07/2022 |
| 22 | BASEMENT CUSTODIANS ROOM | | | | 11/07/2022 |
| 2 | BASEMENT ROOM NEXT TO BOYS RM | | | | 11/07/2022 |
| 22 | BASEMENT KITCHEN BASEMENT | | | | 11/07/2022 |
| 2 | KITCHEN BASEMENT | | | | 11/07/2022 |
| 2 | KITCHEN BASEMENT | | | | 11/07/2022 |
| . <u>. </u> | BOYS LOCKER ROOM/WEIGH | Т | | | 11/07/2022 |
| <u>7</u> 2 | ROOM BASEMENT BOYS LOCKER ROOM/WEIGH | T | | | 11/07/2022 |
| 7 2 | ROOM BASEMENT BOYS LOCKER ROOM/WEIGH | Т | | | 11/07/2022 |
| | ROOM BASEMENT | 1 | | | 11/01/2022 |

Northeast Integrated Systems Page 15 of 18

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|------------|--|--------------|-------|--------|--------------|
| Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | | | | 11/07/2022 |
| Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | • | | | 11/07/2022 |
| Z2 | BOYS LOCKER ROOM STORAGE BASEMENT | | | | 11/07/2022 |
| Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | • | | | 11/07/2022 |
| Z2 | BOYS LOCKER ROOM/WEIGHT ROOM BASEMENT | | | | 11/07/2022 |
| Z2 | GIRLS LOCKER ROOM BASEMENT | | | | 11/07/2022 |
| Z2 | GIRLS LOCKER ROOM BASEMENT | | | | 11/07/2022 |
| Z2 | GIRLS LOCKER ROOM BASEMENT | | | | 11/07/2022 |
| Z2 | GIRLS LOCKER ROOM BASEMENT | | | | 11/07/2022 |
| Z3 | PRINCIPALS OFFICE 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION CONFERENCE ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z 3 | ADMINISTRATION TELEPHONE ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION BATH ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | KITCHEN BEHIND MAIN OFFICE 1ST FLOOR | | | | 11/07/2022 |
| Z3 | RESTROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | TEACHERS RESTROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | TEACHERS LOUNGE 1ST FLOOR | | | | 11/07/2022 |
| Z3 | STORAGE SODA CLOSET 1ST FLOOR | | | | 11/07/2022 |
| Z3 | BOYS ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | SCHOOL ADJ COUNSELOR ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | SCHOOL ADJ COUNSELOR BATHROOM 1ST FLOOR | | | | 11/07/2022 |
| Z4 | HALL O/S ROOM 214a 2ND FLOOR | | | | 11/07/2022 |
| Z4 | HALL O/S ROOM 221 2ND FLOOR | | | | 11/07/2022 |
| Z4 | STAFF RESTROOM 2ND FLOOR | | | | 11/07/2022 |
| Z4 | ROOM 218 2ND FLOOR | | | | 11/07/2022 |
| Z4 | ROOM 221 2ND FLOOR | | | | 11/07/2022 |
| Z4 | ROOM 255 2ND FLOOR | | | | 11/07/2022 |
| Z 5 | 3rd BATHROOM 306 3RD FLOOR | | | | 11/07/2022 |
| Z5 | GIRLS ROOM 3RD FLOOR | | | | 11/07/2022 |
| Z 5 | SCIENCE ROOM 309 3RD FLOOR | | | | 11/07/2022 |
| Z5 | SCIENCE ROOM 309 3RD FLOOR | | | | 11/07/2022 |
| Z5 | ROOM 355 3RD FLOOR | | | | 11/07/2022 |
| Z 5 | STORAGE ROOM 3RD FLOOR | | | | 11/07/2022 |
| Z5 | BOYS ROOM 3RD FLOOR | | | | 11/07/2022 |
| Z4 | GIRLS ROOM 2ND FLOOR | | | | 11/07/2022 |
| Z4 | RESTROOM 2ND FLOOR | | | | 11/07/2022 |
| Z4 | ROOM 220 2ND FLOOR | | | | 11/07/2022 |
| Z4 | ROOM 219 2ND FLOOR | | | | 11/07/2022 |
| Z4 | BOYS ROOM 2ND FLOOR | | | | 11/07/2022 |
| Z3 | TEACHERS LOUNGE 1ST | | | | 11/07/2022 |
| Z3 | FLOOR TEACHERS LOUNGE CLOSET | | | | 11/07/2022 |
| | 1ST FLOOR | | | | |

Northeast Integrated Systems Page 16 of 18

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------|---|--------------|-------|--------|--------------|
| Z3 | WORK ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | WORK ROOM 2 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION COAT ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION O/S COAT ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION PSYCHOLOGIST ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION FILE ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION OFFICE 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION OFFICE@FACU 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION O/S BATH ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | PRINCIPALS OFFICE STORAGE 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ADMINISTRATION CONFERENCE BATHROOM ROOM 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ROOM 100 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ROOM 101 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ROOM 99 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ROOM 99 1ST FLOOR | | | | 11/07/2022 |
| Z3 | ROOM 99 1ST FLOOR | | | | 11/07/2022 |
| Z3 | HALL O/S ROOM 99 1ST FLOOR | | | | 11/07/2022 |
| Z2 | KITCHEN STORAGE BASEMENT | | | | 11/07/2022 |
| Z2 | KITCHEN STORAGE BASEMENT | | | | 11/07/2022 |
| Z2 | KITCHEN STORAGE BASEMENT | | | | 11/07/2022 |
| Z2 | BOYS ROOM BASEMENT | | | | 11/07/2022 |
| Z 2 | ROOM B6B BASEMENT | | | | 11/07/2022 |
| Z1 | ELECTRICAL ROOM SUB- BASEMENT | | | | 11/07/2022 |
| Z2 | GIRLS ROOM BASEMENT | | | | 11/07/2022 |
| Z2 | ROOM B52 BASEMENT | | | | 11/07/2022 |
| Manual Pull Station | | | | | |
| Z2 | HALL O/S B6 BASEMENT | | | | 11/07/2022 |
| Z2 | HALL O/S B17 BASEMENT | | | | 11/07/2022 |
| Z2 | HALL O/S ELEVATOR BASEMENT | | | | 11/07/2022 |
| Z2 | HALL O/S ROOM B3 BASEMENT | | | | 11/07/2022 |
| Z3 | HALL O/S ROOM 112 1ST FLOOR | | | | 11/07/2022 |
| Z3 | HALL O/S ROOM 107 1ST FLOOR | | | | 11/07/2022 |
| Z3 | HALL O/S ROOM 103 1ST FLOOR | | | | 11/07/2022 |
| Z4 | HALL O/S ROOM 207 2ND FLOOR | | | | 11/07/2022 |
| Z4 | HALL O/S ROOM 203 2ND FLOOR | | | | 11/07/2022 |
| Z5 | HALL O/S ROOM 307 3RD FLOOR | | | | 11/07/2022 |
| Z5 | HALL O/S ROOM 317 3RD FLOOR | | | | 11/07/2022 |
| Z5 | HALL O/S ROOM 313 3RD FLOOR | | | | 11/07/2022 |
| Z5 | HALL O/S ROOM 303 3RD FLOOR | | | | 11/07/2022 |
| Z4 | HALL O/S ROOM 217 2ND FLOOR | | | | 11/07/2022 |

Northeast Integrated Systems Page 17 of 18

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE | | |
|-----------------------|------------------------------------|--------------|----------|--------|--------------|--|--|
| Smoke Detector | | | | | | | |
| Z3 | MWR RESTROOM 1ST FLOOR | | | | 11/07/2022 | | |
| Power Supplies | | | | | | | |
| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE | | |
| Battery - Sealed Lead | Battery - Sealed Lead-acid | | | | | | |
| FACU Batteries | 1st Administration Office | SigmasTek | SP12-7.5 | | 07/07/2018 | | |
| Public Emergen | cy Alarm Reporting | | | | | | |
| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE | | |
| Master Box | | | | | | | |
| RMB #1022 | 1st Administration Conference Room | AES | 7750-F-8 | | 11/07/2020 | | |