



April 1, 2026

To All Proposers:

Subject: **RFP No. CR-8655-W6, Maintenance: Aquatic Facilities / DPRC**

ADDENDUM NO. 3

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

- **PLEASE SEE BELOW QUESTIONS RECEIVED AND RESPONSES FROM CITY:**

What is the tile/roll installation at East Park? Is there manufacturer/spec we should assume?

Answer: The tile / roll installation at East Park consists of a system that allows for water drainage either below or on top of the installed product, is interlocking without tools or installed using an approved adhesive, is UV, mold, stain, chemical, slip, and fade resistant. Product must be accessible, have beveled or transition edges if required and is designed to reduce expansion, flexibility, and contraction due to temperature changes. Acceptable product manufacturers are as follows: American Floor Mats for Pools & Wet Outdoor Facilities, Life Floor Aquatic Flooring and Aqua Seal Resurfacing LLC.

City will approve / select final product to be used.

Proposers are requested to acknowledge and/or include this addendum with submission. All other terms, conditions, and specifications remain unchanged.

Christopher J. Gagliastro
Purchasing Director