



The City of **WORCESTER**

Administration & Finance – Purchasing Division
Christopher J. Gagliastro, MCPPO – Purchasing Director
455 Main Street, Room 201, Worcester, MA 01608
P | 508-799-1220
purchasing@worcesterma.gov

July 13, 2026

To All Bidders:

Subject: **Bid No. CR-8754-J7 – Emergency Eyewash and Shower Annual Inspections / WPS**

ADDENDUM NO. 1

To Whom It May Concern:

With reference to our bid request relative to the above subject, please refer to the changes/modifications/clarifications to the original proposal request.

Questions received by this office and responses from The City:

1. How will access to all facilities be handled? Are appointments required for each specific facility or will access be granted at the time of arrival?
 - a. The awarded vendor shall provide a schedule of buildings for when testing will occur so Facilities can arrange access.
2. Are there any credentials (besides 3 year experience), Cori information or other background information required for our on-site service providers?
 - a. The governing standards (ANSI Z358.1 and OSHA 29 CFR 1910.151(c)) require competent, trained personnel, not licensed plumbers, for weekly activation tests and annual inspections.
3. Will the full 15-minute flow time be required for each and every unit within any particular facility? (typical industry testing with multiple units within a facility is to do the 15 minute rate for a few units and each of the others tested for a shorter length of time. This will alleviate the waste of a tremendous amount of water).
 - a. Yes. All fixtures must undergo the full 15-minute flow test to confirm continuous delivery of 20 gpm for the entire duration, as well as compliance with the required tepid water range of 60–100°F.

Bidders are requested to acknowledge and/or include this addendum with submission. All other terms, conditions and specifications remain unchanged.

Very truly yours,

Jerry Kucera
Buyer