

ADDENDUM No. 6 – April 10, 2026

PART 1 - GENERAL

Note: All Addenda must be acknowledged on the bid form.

This addendum modifies, amends, and supplements designated parts of the Contract Documents for the above project and is hereby made part thereof by reference and shall be as binding as though inserted in locations designated hereunder.

It shall be the responsibility of the bidders to notify all subcontractors and suppliers he proposes to use for the various parts of the work for any changes or modifications contained in this addendum. No claim for additional compensation because of lack of knowledge of the contents of this addendum will be considered.

PART 2 – SPECIFICATIONS

1. SECTION 12 30 00 – CASEWORK

Page 10, Part 2:

- Insert: “2.14. STAINLESS STEEL COUNTER
- A. Material: 16-gauge, type 304, stainless steel with matte finish on moisture resistance moisture resistant plywood substrate.
 - B. Edge Profile: Square edge with eased or rounded corners and returned to the cabinet front below the substrate.
 - C. Size: As shown on the drawings.”

PART 3 – DRAWINGS

1. DRAWING 8.2 – ENLARGED PLAN & ELEVATIONS @ TEACHING HUB, EXAM ROOMS

Elevation 8/A8.2 Teaching Hub View D322 South

Delete: Drawing note “Custom 9’-0”L x 9’-0”H vinyl graphic-die cut sign centered on wall.”

Insert: Drawing note “Sign type 7A, as shown on drawing 5/A12.1. Center the sign between the wall openings.”

2. DRAWING A12.1 – SIGNAGE SCHEDULE

Detail 5/A12.1

Delete: Drawing title “Sign Type 7A “Tufts @ Tech Vinyl Sign

Insert: Drawing title “Sign Types 7A & 7B “Tufts @ Tech” Vinyl Die-Cut Sign

Detail 5/A12.1

Insert: Note “Sign type 7A shall be 9’-0”long x 4’-0”high. As shown in elevation 8/A8.2 Teaching Hub View D322 South”

PART 3 – DRAWINGS CONTINUED

Insert: Note “Sign type 7B shall be 27’-8” +/- long x 3’-2” +/- high. The final size shall be field verified to fit within the existing hollow metal frame and mullions, as shown in elevation 5/A8.1 SURGERY D322M-SOUTH.”

PART 4 – ATTACHMENTS

1. NONE

PART 5 – RFI’S AND RESPONSES

QUESTION	RESPONSE
<p>We were reviewing the signage documents for the Worcester Technical High School Tufts Vet Tech Clinic Renovation and could not locate the dimensions for Sign Types 7A and 7B.</p> <p>On drawing A12.1, the signage schedule references the elevation for size and location, but we were only able to identify the locations and not any actual dimensions for these vinyl graphics.</p> <p>Can you please confirm the required sizes for Sign Types 7A and 7B, or issue a sketch/detail/addendum showing the intended dimensions?</p>	<p>See Part 3, notes 1 & 2 of this addendum.</p>
<p>We do not see any specifications for the stainless steel countertops that go with lab casework. Could you please provide?</p>	<p>See Part 2, note 1 of this addendum.</p>

END OF ADDENDUM NO. 6